



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0463 Rev.1

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

**Intelligent analogue addressable fire alarm sounder
SensolRIS WSOU-xx, MAGPRO-WS, Belinda WSOU-xx, Erida WSOU-xx,
Marl WSOU-xx, Smoke sense WSOU-xx**

For specifications see Annex 1 and Annex 2 to this certificate

placed on the market under the name or trade mark of

**Teletek Electronics JSC
14A Srebarna Str., 1407 Sofia, Bulgaria**

and produced in the manufacturing plant

**Teletek Electronics JSC
14A Srebarna Str., 1407 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-3:2001


EN 54-3:2001/A1:2002

EN 54-3:2001/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the


constancy of performance of the construction product.

This certificate was first issued on August 14th, 2017 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, August 14th, 2017

053173


Marek Hudák
Director NB

Annex 1 to Certificate No. 1293 - CPR – 0463 Rev.1 from August 14th, 2017

Technical Specifications


SensoIRIS WSOU-xx, MAGPRO-WS, Belinda WSOU-xx, Erida WSOU-xx, Marl WSOU-xx, Smoke sense WSOU-xx is an addressable Wall Mount Sounder designed for installing in addressable fire alarm systems supporting TTE communication protocol.

The device is powered on from the panel and can be controlled via the communication protocol.

The device is compatible with fire bases B124 for ceiling mounting and WSB IP65 for wall mounting.

Products parameters:

Operating Voltage Range:	15 - 32VDC (Nom. 27VDC)
Nominal consumption (stand-by):	<500 μ A@27VDC
Maximal consumption (main tone type 27):	
- low volume level	<5mA
- high volume level	<16,5mA
Maximal consumption (other tone types):	
- low volume level	<4mA
- high volume level	<10mA
Power volume (main tone type 27):	
- low volume	~ 80dB (A) \pm 6dB @ 1m
- high volume	~ 92dB (A) \pm 5dB @ 1m
Power volume (other tone types):	
- low volume	75-85dB \pm 3dB @ 1m
- high volume	80-95dB \pm 3dB @ 1m
Number of tone types:	32
Wire Gauge for terminals:	2.5mm ²
Degree of protection:	IP43C(EN54-3) with base B124
Degree of protection:	IP 65(EN60529) with base WSB IP65
Operation temperature:	-10°C + +50°C
Relative humidity:	(93 \pm 3)% @ +40°C
Dimensions:	55x116mm
Weight:	183g
Color WSOU-xx (according the model):	
- WSOU-R	red
- WSOU-WT	white transparent
- WSOU-AT	amber transparent
- WSOU-RT	red transparent
MAGPRO-WS	red
Material (according the model):	
- WSOU-R	ABS
- WSOU-WT	SAN
- WSOU-AT	SAN
- WSOU-RT	SAN
MAGPRO-WS	ABS



Nová Dubnica, August 14th, 2017

Marek H u d á k
Director NB

Annex 2 to Certificate No. 1293 - CPR – 0463 Rev.1 from August 14th, 2017

Essential characteristics	Test specification	Harmonised technical specifications	Performance
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1=N/A, C.5.2=N/A, C.5.3=N/A	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	Pass
Operational reliability	cl. 4.4, 4.5, 4.6, 5.4, C4=N/A	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	Pass
Durability of operational reliability and response delay: temperature resistance	cl. 5.5, 5.6, 5.7, 5.8, 5.9	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	Pass
Durability of operational reliability: humidity resistance	cl. 5.8, 5.9, 5.10	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.12 to 5.15	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	Pass
Durability of operational reliability: electrical stability	cl. 5.16	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	Pass
Durability of operational reliability: resistance to ingress	cl. 5.17	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0463	Original certificate issued	February 2 nd , 2015
2	1293-CPR-0463 Rev.1	Change of Installation Instructions	August 14 th , 2017



Nová Dubnica, August 14th, 2017

053185


Marek Hudák
Director NB

